

WATER QUALITY REPORT

FOR THE YEAR ENDED 31 DECEMBER 2002

Microbiological quality

Water leaving treatment works

Supply point & average daily volume distributed from Works (MI/d)	No. of samples	% samples exceeding prescribed concentration or value	
		Total coliforms	Faecal coliforms
Handois (10.3 MI/d)	1043	0	0
Augres (9.4 MI/d)	365	0	0
Total (19.7 MI/d)	1408	0	0

Water in service reservoirs

Capacity of Reservoirs (MI)	No. of samples	% samples exceeding prescribed concentration or value	
		Total coliforms	Faecal coliforms
Westmount 9 MI	362	0	0

Water in distribution

Zone	No. of samples	% samples exceeding prescribed concentration or value (number of samples exceeding concentration of value)	
		Total coliforms	Faecal coliforms
Zone 1: East			
Random consumer taps	68	0	0
Fixed points	430	0	0
Total	498	0	0
Zone 2: West			
Random consumer taps	57	1.75 (1)	0
Fixed points	279	0.36 (1)	0
Total	336	0.60 (2)	0

Samples exceeding prescribed concentrations were immediately resampled for three consecutive days - recheck samples were clear.