

2020

Water Quality Report

The Jersey New Waterworks Company Limited





Contents

- 2** Executive Summary
- 3** Water Quality Team
- 4** Oversight of Water Quality
- 5** Supply Points and Supply Zone Regulatory Results
- 8** Consumer Contacts and Enquiries
- 10** Raw Water Quality
- 11** Understanding Test Results
- 12** Appendix

Executive Summary



Jersey Water exists to supply the water needed for the island to thrive, today and everyday. The provision of clean, safe water is core to our mission and during the year ended 30 September 2020 (‘the year’), extremely high standards were again achieved.

Jersey Water supplied high-quality drinking water with an overall compliance rate of 99.98%, slightly ahead of 99.97% in 2019. As for last year, Jersey Water met 100% compliance with water quality standards for nitrates and pesticides. The bacteriological compliance of the water supplied was 100% for *E.coli* (2019: 100%) and 99.89% for total coliforms (2019: 99.51%).

During the year, the Company completed 14,586 analyses on treated water samples and of these, only three were outside of their respective regulatory water quality parameter but posed no threat to health¹. They were quickly rectified.

2020 was the 7th consecutive year of full compliance with regulatory limits for nitrates. The maximum concentration detected in treated water was 45.4mg/l, below the regulatory limit of 50mg/l but an increase on the unusually low 2019 value of 34.5 mg/l.

The increase in concentrations compared to last year was mainly due to a wet winter resulting in increased run-off, and the recharge of aquifers resulting in more significant streamflow.

In 2020, Jersey adopted a new risk-based approach to raw water quality monitoring for pesticides, analysing reservoir outlets at a weekly frequency using a "broad sweep" analysis capable of identifying the presence of 450 different pesticides. The change in approach maintained a high level of vigilance over the quality of water taken for treatment. Testing during the year identified 54 (2019: 35) detections of pesticides at 0.1µg/l or greater in the reservoirs. The increase is attributed to wetter conditions during the growing season. Careful selection of which reservoir to use and treatment ensured that there were no breaches of the pesticide limit in treated water.

From April 2019, Jersey Water has voluntarily amended its drinking water monitoring program for PFAS (poly and perfluoroalkyl substances) and increased the frequency of testing above that which would be required under the Water (Jersey) Law 1972. Results of the analysis confirmed full compliance with applicable regulatory limits (2019: 100%) for all water supplied by Jersey Water.

Fewer consumers contacted Jersey Water with enquiries and slightly more with water quality issues, compared to the England and Wales (E&W) industry averages. This increase was principally down to two separate incidents concerning discoloured water (in June 2020, generating ten customer contacts and in September 2020, generating 17 contacts). Without these two incidents, the Zone rate would have been 0.92, which is well below the average in England and Wales. These incidents have been reviewed and the lessons learned are being used to improve Jersey Water's practices to minimise the impact of similar incidents on consumers in the future.

There has been a slight increase in the proportion of contacts regarding the taste or odour of the water supplied by Jersey Water from 17% in 2019 to 23% in the year. These had no health risks associated and work to improve the acceptability of water to consumers in terms of taste and odour is on-going.


¹The three samples were one for Total Coliforms and two for Odour in the water.

Water Quality Team

Jersey Water's Water Quality Team is part of the wider Water Supply Team and comprises specialists in chemistry, microbiology, data analysis and sampling. The team works out of the Millbrook Laboratory where a range of microbiological and chemical analyses are carried out on a 7-day a week basis.

The team is responsible for the sampling, analysis and reporting required to ensure our customers receive safe, clean drinking water whenever they want it. The team works very closely with other Jersey Water colleagues responsible for all parts of the water supply chain, providing support and advice on issues affecting water quality.

The team also supports wider activities in Jersey. During 2020 they provided help to Government of Jersey departments including Environment and Environmental Health as well as technical support to the Action for Cleaner Water Group and the Government of Jersey Officer Technical Group on PFAS.



Action for Cleaner Water Group Film

Oversight of Water Quality

Jersey Water operates under the legislative requirements set out in the Water (Jersey) Law 1972. Article 10 places a duty on Jersey Water to develop an annual monitoring programme and to submit that programme to the Minister of Environment each year for approval.

In response to the Covid-19 pandemic and with regulatory approval by the Minister, the company amended its monitoring regime for 2020 to take account of the restrictions put in place to ensure the safety of both Jersey Water's customers and employees.





Supply Points and Supply Zone Regulatory Results

Jersey Water adopts a risk-based water quality monitoring programme consistent with other water suppliers in Europe and elsewhere. This approach is consistent with the Company's Drinking Water Safety Plan where potential risks are evaluated and water quality testing is designed to help manage those risks.

The Company examined samples from supply points including our two treatment works at Handois and Augrés, service reservoirs at Westmount and Les Platons and the supply zone (also known as the distribution network) for compliance purposes at regular intervals throughout the year.

The Company undertakes two kinds of regulatory water quality monitoring - check and audit monitoring. Check monitoring is more frequent and is designed to ensure the treatment works are operating as expected and that the water in distribution is suitable for supply. Audit monitoring is performed less frequently and is designed to test the quality of the water supplied against the full requirements of the Water (Jersey) Law 1972.

Overall compliance

Due to alignment with the change in financial reporting for Jersey Water, the 2020 report is based on the year ended 30 September 2020 (the 'Year' or '2020').


Water quality in 2020 was extremely high with only three non-compliant regulatory analyses identified out of **14,586 analyses taken** for compliance purposes, none of which were harmful to health.

Overall water quality **compliance for 2020 was 99.98%**. This is a slight improvement on the result for 2019 which had a compliance rate of 99.97%.

Treatment works performance (supply points)

The Company samples water leaving the treatment works to ensure that it complies with regulatory parameters before it enters the mains network. During the year the Company undertook **424 sampling events** resulting in **11,502 analyses** covering 139 physical, bacteriological and chemical parameters. All of the analyses were compliant with the regulatory limits.

Detailed supply point results are set out in Appendix 1, 2, 3 and 4.



Service reservoir performance

To comply with regulations, weekly microbiological and residual disinfection samples are taken from the service reservoirs to ensure there has been no deterioration in the water quality during storage. During the year **761 analyses** were undertaken on **177 samples** all of which complied with the regulations except for a single failure for coliform bacteria.

- The single analysis outside the permitted range was for coliform bacteria, detected in a sample taken from the outlet to Les Platons East Service Reservoir. Investigations showed all the disinfection processes and turbidity were satisfactory and the repeat samples taken were negative for coliform bacteria; on this basis it was concluded that there was no risk to drinking water quality for our customers.

| | |
|-------------------------------|---------------------------------------|
| Parameter | Coliform Bacteria |
| Date | 10/01/20 |
| Analysis Type | Check Analysis |
| Concentration Recorded | 14 MPN per 100ml |
| Regulatory Limit | 0 MPN per 100ml (in 95% of sample) |

For water to be deemed wholesome leaving an individual service reservoir there has to be a 95% or greater compliance with the coliform bacteria regulatory limit. The Company achieved 98.1% compliance with the regulatory limit for coliform bacteria and therefore demonstrably supplied wholesome water.

Detailed service reservoir results are set out in Appendix 5.

Water quality in the distribution system (supply zone)

114 water samples were taken at randomly selected customer properties from all parts of the distribution system between 1 October 2019 and 11 March 2020 then, once restrictions were in place due to Covid-19 and with the approval of the Minister³, 189 water samples were taken from fixed points around the distribution system. Of 2,323 analyses taken throughout the year all were compliant with regulatory limits except for two.

The two analyses outside the permitted range were for odour, detected in samples taken from a kitchen tap at a randomly selected property and at one of the fixed points in the distribution system. Investigations showed all the disinfection processes and turbidity were satisfactory at the treatment works and repeat samples taken from the affected taps were negative for odour.

| | | |
|-------------------------------|-------------------------------|--------------------|
| Parameter | Odour, random consumer sample | Odour, fixed point |
| Date | 18/12/19 | 09/06/20 |
| Analysis Type | Check Analysis | Check Analysis |
| Concentration Recorded | 5 Dil. No. | 4 Dil. No. |
| Regulatory Limit | 3 Dil. No. @ 25°C | 3 Dil. No. @ 25°C |

Detailed supply zone results are set out in Appendix 6 and 7.

Consumer Contacts & Enquiries

Every contact and enquiry received by Jersey Water is recorded and categorised whether or not they require a visit to rectify an issue. The categories used are modeled on The Drinking Water Inspectorate for England and Wales' Information letter 1/2006⁴. The contacts for the year are listed on the table below with the sub-categories referencing the DWI Information Letter categories):

Consumer contacts

| | 2020 | 2019 | 2018 |
|---------------------------------------|-------------------|-------------------|-------------------|
| Total Consumer Enquiries ^d | 3 | 5 | 10 |
| Total Contacts ^e | 5 | 7 | 8 |
| Zonal Total | 8 | 12 | 18 |
| Zone rate (per 1000 population) | 0.09 | 0.13 | 0.20 |
| England & Wales industry average | 0.30 ^a | 0.45 ^b | 0.50 ^c |

⁴www.ofwat.gov.uk/wp-content/uploads/2019/12/DWI-Customer-contacts-about-water-quality-taste-and-odour.pdf

^a2019 figures, ^b2018 figures, ^c2017 figures

^dA consumer contact about drinking water quality is any communication about drinking water quality initiated by a consumer in the absence of any expression of concern, dissatisfaction or service shortfall.

^eA consumer contact about a water quality concern is a contact where the consumer expresses a concern about drinking water other than its appearance, taste or smell and they are not attributing symptoms of a current illness to the water.



Acceptability of Water to Consumers

| Type of Complaint | 2020 | 2019 | 2018 |
|--------------------------------------|-------------------|-------------------|-------------------|
| Appearance (section 4.3) | | | |
| Discoloured water | 43 | 25 | 32 |
| Blue water | 4 | 0 | 0 |
| Particles | 3 | 4 | 2 |
| Air in water | 9 | 8 | 16 |
| Chalky appearance | 2 | 0 | 2 |
| Animalcules | 0 | 0 | 0 |
| General | 13 | 26 | 9 |
| Appearance (total) | 74 | 63 | 61 |
| Taste and Odour (section 4.4) | | | |
| Chlorine | 2 | 4 | 8 |
| Earthy/musty | 3 | 4 | 3 |
| Petrol/diesel | 0 | 0 | 0 |
| Other | 22 | 9 | 22 |
| Tate and Odour (total) | 27 | 17 | 33 |
| Alleged Illness (section 4.5) | | | |
| Gastroenteritis | 7 | 0 | 2 |
| Oral | 0 | 0 | 0 |
| Skin | 1 | 6 | 2 |
| Medical opinion | 1 | 1 | 2 |
| Alleged Illness (total) | 9 | 7 | 6 |
| Zonal Total | 110 | 87 | 100 |
| Zone rate (per 1000 population) | 1.22 | 0.97 | 1.11 |
| England & Wales industry average | 1.20 ^a | 1.31 ^b | 1.31 ^c |

Fewer consumers contacted Jersey Water with enquiries and slightly more with water quality issues, compared to the England and Wales industry averages. This increase was principally down to two separate incidents around discoloured water (June 2020 generating 10 contacts: September 2020 generating 17 contacts). Without these two incidents the Zone rate would have been 0.92 which is well below the average in England and Wales. These incidents have been reviewed and the lessons learned are being used to improve Jersey Water's practices to minimise the impact of similar incidents on consumers in the future.

There has been a slight increase in the proportion of contacts regarding the taste or odour of the water supplied by Jersey Water from 17% in 2019 to 23% in 2020. Work to improve the acceptability of water to consumers in terms of taste and odour is on-going.

There were eight contacts for water quality information in 2020 which was a slight decrease in consumer enquiries. They covered a range of topics mainly relating to dishwasher settings and water hardness (typically 120 – 150 mg/l as CaCO₃). More information on this can be found on the Company website under the appliance settings (dishwashers) tab

Bacteriological and chemical samples were taken where the consumer had suspected the water supply to be causing illness. When Jersey Water staff visit a property to investigate consumer contacts bacteriological samples are routinely taken; all such samples in the year were found to be compliant with the Regulations.

^awww.jerseywater.je/water-quality/water-quality-faq

^a2019 figures, ^b2018 figures, ^c2017 figures

Raw Water Quality

For operational and monitoring purposes Jersey Water takes samples of water from streams, reservoirs and the inlet to the treatment works. This enables our operational staff to select the most suitable waters to be taken for treatment.

Nitrates

While nitrates in treated water reached a peak of 45.4mg/l in April 2020, below the regulatory limit of 50mg/l, this was only possible through the careful selection and blending of raw water during the potato growing season and the availability of low nitrate water collected in the reservoirs before the growing season began.

Concentrations of nitrates in raw water peaked at 146.4 mg/l in September 2020 in the Queen's Valley Side Stream catchment and averaged 52.3 mg/l throughout the Island during the year, up from 46.1 mg/l in 2019. This is most likely due to the wet winter experienced this year, increasing run off and raising ground water levels.

Pesticides

A risk assessment for the year was undertaken for monitoring pesticides in the raw water resources used by Jersey Water. The decision was made to concentrate on ensuring the water taken from the reservoirs and sent for treatment was the best available. Weekly monitoring of all the reservoirs using an analytical method which provides a broad scan for 450 substances was undertaken which enabled the Company to quickly identify if there were any issues.

During 2020, 54 detections were made at 0.1 µg/l or greater but by careful selection of which reservoir to use and treatment, there were no breaches of the pesticide limit in treated water.

PFAS

Drinking water supplied by Jersey Water has been tested for PFAS (poly and perfluoroalkyl substances) since 1989. Based on the results of this testing the drinking water supply in Jersey has been fully compliant with the water quality requirements of the Water (Jersey) Law 1972 and meets the definition of wholesomeness against which drinking water quality is assessed. Results of drinking water testing for 2020 (Appendix 4) show either no detections for PFAS or detections well within the UK DWI guidance.

Further details on PFAS can be found in the update report from the Government of Jersey Officer Technical Group⁶.

⁶<https://www.gov.je/SiteCollectionDocuments/Environment%20and%20greener%20living/R%20PFAS%20and%20water%20quality%20in%20Jersey%202020%2006112020%20TDF%20v1.pdf>

Understanding Test Results

Regulatory Analyses

The Water (Jersey) Law 1972 as amended requires two types of monitoring at the treatment works and service reservoir outlets and in the distribution system:

- Check monitoring**
 Tests performed on a frequent basis to ensure that the treatment works and the water in distribution is suitable for supply.
- Audit monitoring**
 Testing performed less frequently than check monitoring and which is designed to test the quality of the water supplied against the full requirements of the Water (Jersey) Law 1972.

| Term | Description |
|---|---|
| CFU | Colony forming units (CFU), a physical count of the number of colonies of bacteria visible on a membrane or an agar plate. |
| % Compliance | The percentage of the results that comply with the regulatory limit. |
| µg/l | Micrograms per litre or parts per billion, (equivalent to 1p in £10,000,000) |
| µS/cm | The unit of measure commonly used for electrical conductivity in water, micro Siemens/cm. |
| Max | The maximum or highest result produced for that test. |
| Mean | The average value of all the results produced for that test. |
| Min | The minimum or lowest result produced for that test. |
| MPN | The most probable number (MPN) is a statistical method used to estimate the viable numbers of bacteria in a sample. |
| PAC | Powdered Activated Carbon – used to aid in the removal of impurities in water such as pesticides during the treatment process. |
| PFAS | <p>PFAS is short for poly and perfluoroalkyl substances. PFASs are a class of more than 4,000 different chemicals, and they are everywhere e.g. they turn up in everything from household items to fast food wrappers.</p> <p>Some of the most commonly used PFAS chemicals, like PFOS and PFOA (perfluorooctanesulfonic acid and perfluorooctanoic acid) have long half-lives meaning they will persist in the environment for long periods of time.</p> |
| Sample Point | The location where the sample was taken |
| Specific concentration or value (maximum) or state | The maximum or range of values allowed by law in the water supply (regulatory limit). |
| Substances and parameters | The item we are testing for. |

Appendix 1⁷:

2020 Treatment Works Performance Check Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Sample Point | Min | Mean | Max | Compliance (%) | What it means |
|-------------------------|---|---------------------|--------------------|-------|-------|----------------|---|
| <i>E.coli</i> | 0 MPN per 100ml | Augrés Final Water | 0 | 0 | 0 | 100 | Primary indicator of faecal contamination of treated water |
| | | Handois Final Water | 0 | 0 | 0 | 100 | |
| Coliform bacteria | 0 MPN per 100ml | Augrés Final Water | 0 | 0 | 0 | 100 | Detection of coliform bacteria may indicate sub-optimal operation of the treatment process or ingress of contamination from breaches in the integrity of the distribution system. |
| | | Handois Final Water | 0 | 0 | 0 | 100 | |
| Colony counts | No abnormal change | Augrés Final Water | No abnormal change | | | 100 | Monitoring water supplies for colony count bacteria can be useful for monitoring trends in water quality or detecting sudden changes in quality |
| | | Handois Final Water | | | | 100 | |
| Nitrite | 0.1 mg NO ₂ /l | Augrés Final Water | <0.003 | 0.010 | 0.081 | 100 | Nitrite may be associated with nitrate or with the use of ammonia in water disinfection. |
| | | Handois Final Water | <0.003 | 0.011 | 0.052 | 100 | |
| Residual disinfectant | No value mg Cl ₂ /l | Augrés Final Water | 0.22 | 0.49 | 0.64 | | Sufficient chlorine is added to all supplies to ensure the absence of harmful microorganisms. |
| | | Handois Final Water | 0.35 | 0.52 | 0.65 | | |
| Turbidity | 1 NTU | Augrés Final Water | 0.06 | 0.09 | 0.13 | 100 | The Standard requires that there should be no haziness caused by fine particles. |
| | | Handois Final Water | 0.06 | 0.10 | 0.14 | 100 | |
| Conductivity | 2500 µS/cm at 20°C | Augrés Final Water | 418 | 498 | 560 | 100 | A measure of the ability of the water to conduct an electric current and therefore a measurement of the mineral salts dissolved in the water. |
| | | Handois Final Water | 439 | 510 | 558 | 100 | |

⁷In these tables 'Augrés Final Water' means treated drinking water entering supply from the Augrés Water Treatment Works and, similarly, 'Handois Final Water' means treated drinking water entering supply from the Handois Water Treatment Works.

Appendix 2:

2020 Treatment Works Performance Audit Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Sample Point | Min | Mean | Max | Compliance (%) | What it means |
|--|---|---------------------|---|--------|--------|----------------|--|
| <i>Clostridium perfringens</i> | 0 CFU per 100 ml | Augrés Final Water | 0 | 0 | 0 | 100 | The presence of <i>Clostridium perfringens</i> in filtered water and/or final water may indicate deficiencies in the filtration process (e.g. filter breakthrough) or in the disinfection process. |
| | | Handois Final Water | 0 | 0 | 0 | 100 | |
| Benzene | 1.0 µg/l | Augrés Final Water | All results were below limit of detection from all the sample points. | | | 100 | Benzene may be introduced into source water by industrial effluents or atmospheric pollution. |
| Bromate | 10 µg BrO ₃ /l | | | | | 100 | |
| 1,2 dichloroethane | 3.0 µg/l | Handois Final Water | All results were below limit of detection from all the sample points. | | | 100 | Bromate can be associated with industrial pollution or can occur as a by-product of the disinfection process. |
| Trichloroethene & } Tetrachloroethene } | 10 µg/l | | | | | 100 | |
| Tetrachloromethane | 3 µg/l | | | | | 100 | |
| Boron | 1.0 mg B/l | Augrés Final Water | 0.069 | 0.085 | 0.120 | 100 | Very low levels of these substances may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |
| | | Handois Final Water | 0.058 | 0.087 | 0.122 | 100 | |
| Cyanide | 50 µg CN/l | Augrés Final Water | <2.0 | <2.0 | <2.0 | 100 | |
| | | Handois Final Water | <2.0 | <2.0 | <2.0 | 100 | |
| Fluoride | 1.5 mg F/l | Augrés Final Water | <0.075 | <0.075 | <0.075 | 100 | Occurs naturally in many water sources. The standard is set to ensure no adverse effects. Jersey Water does not artificially fluoridate the water supplies. |
| | | Handois Final Water | <0.075 | <0.075 | <0.075 | 100 | |
| Chloride | 250 mg Cl/l | Augrés Final Water | 47 | 57 | 62 | 100 | Occurs naturally in most water sources. Levels above the standard could give rise to taste issues and contribute to corrosion. |
| | | Handois Final Water | 51 | 62 | 68 | 100 | |
| Sulphate | 250 mg SO ₄ /l | Augrés Final Water | 70 | 81 | 89 | 100 | Dissolves in water after contact with certain mineral deposits. Excess levels can contribute to corrosion. |
| | | Handois Final Water | 65 | 82 | 93 | 100 | |
| Total Organic Carbon | No abnormal change | Augrés Final Water | 1.4 | 1.8 | 2.2 | 100 | This parameter assesses the organic content of the water. |
| | | Handois Final Water | 1.5 | 1.9 | 2.5 | 100 | |
| Gross Alpha | 0.1 Bq/l | Augrés Final Water | <0.020 | <0.020 | <0.020 | 100 | These parameters are measured as part of screening for radioactivity. |
| | | Handois Final Water | <0.020 | <0.020 | <0.020 | 100 | |
| Gross Beta | 1.0 Bq/l | Augrés Final Water | <0.28 | <0.28 | <0.28 | 100 | |
| | | Handois Final Water | <0.28 | <0.28 | <0.28 | 100 | |

Appendix 3:

2020 Treatment Works Pesticide Analysis Audit Monitoring

A suite of 99 pesticides have been analysed during the year at the treatment works outlets. The following table shows the ones that were detected above the limit of detection – there were 83 substances that were not.

| Substances & parameters | Specific concentration/ value (max)/state | Sample Point | Min | Mean | Max | Compliance (%) |
|-------------------------|--|---------------------|--------|--------|--------|----------------|
| 2,4-D | 0.1 µg/l | Augrés Final Water | <0.007 | <0.007 | <0.007 | 100 |
| | | Handois Final Water | <0.007 | <0.007 | 0.011 | 100 |
| Atrazine Desisopropyl | 0.1 µg/l | Augrés Final Water | <0.007 | <0.007 | 0.011 | 100 |
| | | Handois Final Water | <0.007 | <0.007 | 0.010 | 100 |
| Azoxystrobin | 0.1 µg/l | Augrés Final Water | <0.003 | <0.003 | 0.012 | 100 |
| | | Handois Final Water | <0.003 | <0.003 | 0.003 | 100 |
| Bentazone | 0.1 µg/l | Augrés Final Water | <0.007 | <0.007 | 0.011 | 100 |
| | | Handois Final Water | <0.007 | <0.007 | 0.009 | 100 |
| Bromacil | 0.1 µg/l | Augrés Final Water | <0.003 | <0.003 | <0.003 | 100 |
| | | Handois Final Water | <0.003 | <0.003 | 0.005 | 100 |
| Carbendazim | 0.1 µg/l | Augrés Final Water | <0.001 | <0.001 | <0.001 | 100 |
| | | Handois Final Water | <0.001 | <0.001 | 0.002 | 100 |
| Clopyralid | 0.1 µg/l | Augrés Final Water | <0.007 | <0.007 | 0.015 | 100 |
| | | Handois Final Water | <0.007 | <0.007 | 0.010 | 100 |
| Dicamba | 0.1 µg/l | Augrés Final Water | <0.020 | <0.020 | 0.040 | 100 |
| | | Handois Final Water | <0.020 | <0.020 | <0.020 | 100 |
| Diuron | 0.1 µg/l | Augrés Final Water | <0.004 | <0.004 | 0.006 | 100 |
| | | Handois Final Water | <0.004 | <0.004 | <0.004 | 100 |

Appendix 3 (continued):

2020 Treatment Works Pesticide Analysis

Audit Monitoring

A suite of 99 pesticides have been analysed during the 2020 reporting period at the treatment works outlets, the following table shows the ones that were detected above the limit of detection – there were 83 substances that were not.

| Substances & parameters | Specific concentration/ value (max)/state | Sample Point | Min | Mean | Max | Compliance (%) |
|-------------------------|--|---------------------|--------|--------|--------|----------------|
| Fluopicolide | 0.1 µg/l | Augrés Final Water | <0.003 | <0.003 | 0.004 | 100 |
| | | Handois Final Water | <0.003 | <0.003 | 0.007 | 100 |
| Metobromuron | 0.1 µg/l | Augrés Final Water | <0.003 | <0.003 | 0.003 | 100 |
| | | Handois Final Water | <0.003 | 0.009 | 0.060 | 100 |
| Metribuzin | 0.1 µg/l | Augrés Final Water | <0.005 | <0.005 | 0.010 | 100 |
| | | Handois Final Water | <0.005 | <0.005 | <0.005 | 100 |
| Oxadixyl | 0.1 µg/l | Augrés Final Water | 0.009 | 0.019 | 0.040 | 100 |
| | | Handois Final Water | 0.020 | 0.039 | 0.070 | 100 |
| Pendimethalin | 0.1 µg/l | Augrés Final Water | <0.007 | <0.007 | <0.007 | 100 |
| | | Handois Final Water | <0.007 | <0.007 | 0.009 | 100 |
| Propiconazole | 0.1 µg/l | Augrés Final Water | <0.008 | <0.008 | 0.017 | 100 |
| | | Handois Final Water | <0.008 | <0.008 | <0.008 | 100 |
| Tebuconazole | 0.1 µg/l | Augrés Final Water | <0.002 | <0.002 | <0.002 | 100 |
| | | Handois Final Water | <0.002 | <0.002 | 0.002 | 100 |
| Total Pesticides | 0.5 µg/l | Augrés Final Water | 0.012 | 0.029 | 0.073 | 100 |
| | | Handois Final Water | 0.021 | 0.052 | 0.162 | 100 |

Appendix 4:

2020 Treatment Works Per- and polyfluoroalkyl substances (PFAS) Analysis Audit Monitoring⁸

A suite of 17 Per- and polyfluoroalkyl substances (PFAS) have been analysed during the year at the treatment works outlets. All results reported as $\mu\text{g/l}$.

| Per- & polyfluoroalkyl substances | Sample Point | Min | Mean | Max | Compliance (%) |
|--|---------------------|-------|-------|-------|----------------|
| PFBA (357-22-4) Perfluoro-n-butanoic acid | Augrés Final Water | 0.003 | 0.008 | 0.022 | 100 |
| | Handois Final Water | 0.003 | 0.010 | 0.027 | 100 |
| PFPA (2706-90-3) Perfluoro-n-pentanoic acid | Augrés Final Water | 0.002 | 0.004 | 0.011 | 100 |
| | Handois Final Water | 0.002 | 0.005 | 0.008 | 100 |
| PFHxA (307-24-4) Perfluoro-n-hexanoic acid | Augrés Final Water | 0.003 | 0.004 | 0.005 | 100 |
| | Handois Final Water | 0.003 | 0.005 | 0.008 | 100 |
| PFBS (375-73-5) Perfluoro-1-butanefulfonate | Augrés Final Water | 0.003 | 0.003 | 0.004 | 100 |
| | Handois Final Water | 0.004 | 0.005 | 0.006 | 100 |
| PFHpA (375-85-9) Perfluoro-n-heptanoic acid | Augrés Final Water | 0.002 | 0.003 | 0.003 | 100 |
| | Handois Final Water | 0.002 | 0.004 | 0.005 | 100 |
| 6:2PTS (27619-97-2) Perfluoro-octane sulfonate 6:2 | Augrés Final Water | <LoD | <LoD | 0.002 | 100 |
| | Handois Final Water | <LoD | <LoD | 0.003 | 100 |
| PFOA (335-67-1) Perfluoro-n-octanoic acid | Augrés Final Water | 0.003 | 0.004 | 0.005 | 100 |
| | Handois Final Water | 0.004 | 0.008 | 0.029 | 100 |
| PFHxS (355-46-4) Perfluoro-1-hexanesulfonate | Augrés Final Water | 0.002 | 0.004 | 0.008 | 100 |
| | Handois Final Water | 0.004 | 0.006 | 0.012 | 100 |
| PFNA (375-95-1) Perfluoro-n-nonanoic acid | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | 0.001 | 100 |

⁸LoD – Limit of Detection

Appendix 4 (continued):

2020 Treatment Works Per- and polyfluoroalkyl substances (PFAS) Analysis Audit Monitoring⁸

A suite of 17 Per- and polyfluoroalkyl substances (PFAS) have been analysed during the 2020 reporting period at the treatment works outlets. All results reported as µg/l.

| Per- & polyfluoroalkyl substances | Sample Point | Min | Mean | Max | Compliance (%) |
|---|---------------------|-------|-------|-------|----------------|
| PFHpS (375-92-8) Perfluoro-1-heptanesulfonate | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFDA (335-76-2) Perfluoro-n-decanoic acid | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFUnA (2058-94-8) Perfluoro-n-undecanoic acid | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFDoA (307-55-1) Perfluoro-n-dodecanoic acid | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFOSA (754-91-6) Perfluoro-octanesulfonamide | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFDS (335-73-3) Perfluoro-1-decanesulfonate | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| PFPeS (2706-91-4) Perfluoro-1-pentanesulfonate | Augrés Final Water | <LoD | <LoD | <LoD | 100 |
| | Handois Final Water | <LoD | <LoD | <LoD | 100 |
| Total PFOS (sum of linear and branched PFOS) | Augrés Final Water | 0.004 | 0.009 | 0.017 | 100 |
| | Handois Final Water | 0.005 | 0.013 | 0.026 | 100 |
| Total PFAS (sum of all substances listed above) | Augrés Final Water | 0.023 | 0.040 | 0.052 | 100 |
| | Handois Final Water | 0.034 | 0.057 | 0.079 | 100 |

⁸LoD – Limit of Detection

Appendix 5:

2020 Service Reservoir (SR) Performance Check Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Sample Point | Min | Mean | Max | Compliance (%) | What it means |
|-------------------------|---|---------------------|--------------------|------|------|----------------|--|
| <i>E.coli</i> | 0 MPN per 100ml | Les Platons East SR | 0 | 0 | 0 | 100 | Primary indicator of faecal contamination of treated water. |
| | | Les Platons West SR | 0 | 0 | 0 | 100 | |
| | | Westmount SR | 0 | 0 | 0 | 100 | |
| Coliform bacteria | 0 MPN per 100ml (95% of samples) | Les Platons East SR | 0 | 0 | 14 | 98.1 | Detection of coliform bacteria may indicate sub-optimal operation of the treatment process or ingress of contamination from breaches in the integrity of the distribution system. For water to be deemed wholesome leaving a service reservoir there has to be a 95% or greater compliance with the coliform bacteria regulatory limit. |
| | | Les Platons West SR | 0 | 0 | 0 | 100 | |
| | | Westmount SR | 0 | 0 | 0 | 100 | |
| Colony counts | No abnormal change | Les Platons East SR | | | | 100 | Monitoring water supplies for colony count bacteria can be useful for monitoring trends in water quality or detecting sudden changes in quality. |
| | | Les Platons West SR | No abnormal change | | | 100 | |
| | | Westmount SR | | | | 100 | |
| Residual disinfectant | No value mg Cl ₂ /l | Les Platons East SR | 0.05 | 0.15 | 0.42 | 100 | Sufficient chlorine is added to all supplies to ensure the absence of harmful microorganisms. |
| | | Les Platons West SR | 0.06 | 0.16 | 0.39 | 100 | |
| | | Westmount SR | 0.06 | 0.12 | 0.19 | 100 | |

Appendix 6:

Water Quality in the Supply Zone Check Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Min | Mean | Max | Compliance (%) | What it means |
|-------------------------|---|--------------------|------|-------|----------------|---|
| <i>E.coli</i> | 0 MPN per 100ml | 0 | 0 | 0 | 100 | Primary indicator of faecal contamination of treated water |
| Coliform bacteria | 0 MPN per 100ml | 0 | 0 | 0 | 100 | Detection of coliform bacteria may indicate sub-optimal operation of the treatment process or ingress of contamination from breaches in the integrity of the distribution system. |
| Residual disinfectant | No value mg Cl ₂ /l | 0.02 | 0.14 | 0.64 | | Chlorine is added to our water along with ammonia to form a stable chloramine disinfectant compound, to ensure that there are no harmful bacteria in the water we supply. |
| Aluminium | 200 µg Al/l | <5.0 | 12.3 | 53.0 | 100 | Occurs naturally in many water resources. Aluminium compounds are also used at some water treatment works to remove impurities, but are themselves removed in the process |
| Ammonium | 0.50 mg NH ₄ /l | <0.01 | 0.02 | 0.10 | 100 | May be naturally present in some waters and is not harmful. |
| Colony counts | No abnormal change | No abnormal change | | | 100 | Monitoring water supplies for colony count bacteria can be useful for monitoring trends in water quality or detecting sudden changes in quality |
| Colour | 20 mg/l Pt/Co | <0.30 | 1.32 | 7.35 | 100 | Water should be clear and bright but natural organic matter or pipework corrosion products may occasionally impart a slight tint. |
| Conductivity | 2500 µS/cm at 200C | 430 | 514 | 562 | 100 | A measure of the ability of the water to conduct an electric current and therefore a measurement of the mineral salts dissolved in the water. |
| Clostridium perfringens | 0 CFU per 100ml | 0 | 0 | 0 | 100 | The presence of Clostridium perfringens in filtered water and/or final water may indicate deficiencies in the filtration process (e.g. filter breakthrough) or in the disinfection process. |
| Hydrogen ion | 10.0 pH value 6.5 (min) | 7.06 | 7.57 | 7.96 | 100 | A measure of acidity or alkalinity. Excessively acidic or alkaline water can contribute to corrosion of pipes and fittings. |
| Iron | 200 µg Fe/l | <3.0 | 12.1 | 168.8 | 100 | Iron may be associated with the corrosion of old iron mains. The standard has been set for aesthetic reasons as levels persistently above the standard can give rise to discoloured water. |

Appendix 6 (continued):

Water Quality in the Supply Zone Check Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Min | Mean | Max | Compliance (%) | What it means |
|-------------------------|---|--------|-------|-------|----------------|---|
| Manganese | 50 µg Mn/l | <0.9 | 7.0 | 36.6 | 100 | Occurs naturally in many water sources. The standard is set for aesthetic reasons as black deposits of manganese dioxide can give rise to discoloured water. |
| Nitrate | 50 mg NO ₃ /l | 12.1 | 33.7 | 45.4 | 100 | Nitrate arises from the use of fertilisers in agriculture and may be minimised by good practices and appropriate controls. |
| Nitrite | 0.5 mg NO ₂ /l | <0.003 | 0.019 | 0.094 | 100 | Nitrite may be associated with nitrate or with the use of ammonia in water disinfection. |
| Nitrate/Nitrite ratio | 1.000 | 0.254 | 0.681 | 0.916 | 100 | The regulations specify that the ratio according to the following formula must not exceed 1, [nitrate]/50 + [nitrite]/3, where the square brackets signify the concentrations in mg/l for nitrate (NO ₃) and nitrite (NO ₂) respectively. |
| Taste | 3 at 25°C Dilution number | 0 | 0 | 0 | 100 | The water is examined the water for unpleasant taste. This is set for aesthetic reasons. |
| Odour | 3 at 25°C Dilution number | 0 | 0 | 5 | 97.5 | The water is examined the water for unpleasant odour. This is set for aesthetic reasons and does not affect health |
| Turbidity | 4 NTU | 0.07 | 0.17 | 2.36 | 100 | The Standard requires that there should be no haziness caused by fine particles. |
| Cyanide | 50 µg CN/l | <2.0 | <2.0 | <2.0 | 100 | Very low levels may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |

Appendix 7:

Water Quality in the Supply Zone Audit Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Min | Mean | Max | Compliance (%) | What it means |
|-------------------------|---|--------|--------|--------|----------------|--|
| Antimony | 5.0 µg Sb/l | | 0.2 | | 100 | Very low levels may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |
| Arsenic | 10 µg As/l | | <1.0 | | 100 | |
| Benzene | 1.0 µg/l | | <0.02 | | 100 | |
| Boron | 1.0 mg B/l | 0.067 | 0.104 | 0.190 | 100 | Very low levels may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |
| Cadmium | 5.0 µg Cd/l | | <0.12 | | 100 | Very low levels may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |
| Chromium | 50 µg Cr/l | | <0.5 | | 100 | |
| Copper | 2000 µg Cu/l | <4 | 11 | 65 | 100 | Any significant amount of copper is likely to come from corrosion of customers' pipes or fittings. Excess amounts can cause a metallic taste. |
| 1,2 dichloroethane | 3.0 µg/l | <0.12 | <0.12 | <0.12 | 100 | The presence of this organic solvent is an indication of industrial pollution. |
| Enterococci | 0 MPN per 100 ml | 0 | 0 | 0 | 100 | Used to assess the significance of the presence of coliform bacteria in the absence of <i>E.coli</i> or to provide additional information when assessing the extent of possible faecal contamination. They are regarded as secondary indicators of faecal pollution. |
| Fluoride | 1.5 mg F/l | <0.075 | <0.075 | <0.075 | 100 | Occurs naturally in many water sources. The standard is set to ensure no adverse effects. Jersey Water does not artificially fluoridate the water supplies. |
| Gross Alpha | 0.1 Bq/l | <0.020 | <0.020 | <0.020 | 100 | These parameters are measured as part of screening for radioactivity. |
| Gross Beta | 1.0 Bq/l | <0.28 | <0.28 | <0.28 | 100 | |

Appendix 7 (continued):

Water Quality in the Supply Zone Audit Monitoring

| Substances & parameters | Specific concentration/ value (max)/state | Min | Mean | Max | Compliance (%) | What it means |
|--|---|-------|-------|-------|----------------|--|
| Lead | 10 µg Pb/l | <0.9 | <0.9 | <0.9 | 100 | Absent in water entering supply but variable concentrations of lead may be found in water at the customer's tap in older properties built at a time when lead was commonly used in domestic plumbing systems. The standard recognises that the intake of lead should be minimised for health reasons. |
| Nickel | 20 µg Ni/l | <0.6 | 1.4 | 4.0 | 100 | Very low levels may occur naturally, but higher amounts could be associated with industrial pollution. The standards are health related but have a large built-in safety factor. |
| Selenium | 10 µg Se/l | | <0.8 | | 100 | Low levels of selenium may occur naturally in water after it has passed through various mineral deposits and rock strata. Selenium is an essential element and is required as part of the diet. |
| Sodium | 200 mg Na/l | | 56.7 | | 100 | Sodium occurs naturally in water after passing through certain mineral deposits and rock strata or in brackish groundwater. Sodium salts are used extensively in the home and in industrial processes. Domestic water softeners regenerated with brine produce water containing an increased concentration of sodium. Always use unsoftened mains water for drinking, cooking and for preparing babies' feeds. |
| Sum of Trichloroethene & Tetrachloroethene | 10 µg/l | <0.10 | <0.10 | <0.10 | 100 | These substances are organic solvents, their presence is an indication of industrial pollution. |
| Tetrachloromethane | 3 µg/l | <0.11 | <0.11 | <0.11 | 100 | |
| Total Trihalomethanes (THM's) | 100 µg/l | 5.90 | 15.09 | 23.50 | 100 | THM's are formed by the reaction of chlorine added as a disinfectant with naturally occurring organic compounds in the water. |
| Chloride | 250 mg Cl/l | 50 | 60 | 68 | 100 | Chloride can occur naturally in source water and is a component of common salt. The standard is not health-related, but set to avoid taste and corrosion potential. |
| Sulphate | 250 mg SO ₄ /l | 66 | 77 | 92 | 100 | Occurs naturally in many source waters after contact with particular mineral deposits and rock strata. The concentrations normally found in drinking water do not represent a risk to health |
| Total organic carbon | No abnormal change mg/l | 1.4 | 1.8 | 2.2 | 100 | This parameter provides a measure of the total amount of organic matter in water. |